

Type Approval Certificate



This is to certify that the undernoted product(s) has/have been tested in accordance with the relevant requirements of the GL Type Approval System.

Certificate No. 97 910 - 95 HH

Company Bals Elektrotechnik GmbH & Co KG
Burgweg 22
57399 Kirchhundem, GERMANY

Product Description CEE - Socket outlets with plugs

Type 11 556*, 13 021*, 16 050, 17 026, 21 485, 27 027, 31 423

Environmental Category F

Technical Data /
Range of Application 3 poles + PE, 380 / 440V AC, 50 / 60Hz, 32A, thermoplastic enclosure
Degree of protection : IP67

11 556 - Surface-mounting socket-outlet*
13 021 - Panel-mounting socket-outlet*
16 050 - Socket-outlet (switched, mechanical interlocked)
17 026 - Socket-outlet (switched, mechanical interlocked, with DIN rail)
21 485 - Plug GT
27 027 - Panel-mounting appliance inlet
31 423 - Connector GT

Test Standard GL Guidelines for the Performance of Type Approval:2012
EN 60 309-1:2000; EN 60309-2:2000

Documents VDE Licence No.'s: 58912, 85421, 85430, 85431 and 4734 ÜG
MPA NRW test report No.'s: 31 0278 5 95 and 12 0662 1 94
SEMKO test report No.'s: 9411074/5-8, 9411075/2, 9411076/2, 9411077/2

Remarks * = Not accepted for use on board ships

Valid until 2017-10-14

Page 1 of 1

Type Approval Symbol



File No. I.O.02

Hamburg, 2012-10-15

Germanischer Lloyd

W. Voß
Wolfgang Voß

J. Zipfel
Joachim Zipfel